



**ATECPOOL**  
INTERNACIONAL ESPAÑA

World Trade Center Edificio Sur  
2ª Planta - Muelle de Barcelona  
E-08039 Barcelona, Spain  
[+34] 93 34 4 33 58  
info@atecpool.com

### The test certificate for Model 03300090 # 55 KW / 42 KW

The test condition when cooling			
Ambient temp(°C)	48°C	Water flow volume (m³/h)	18m³/h
Voltage (V)	380V	Running time (hrs)	48hrs
Water inlet temp (°C)	38°C	Water outlet temp(°C)	29°C
Testing data when cooling			
Test term	Unit	System 1	System 2
Running current	A	11.1 - 11 - 11.2	11.3 - 11.1 - 11.6
Low pressure	MPa	0.63	0.66
Compressor gas outlet temp.	°C	90	84
The test condition when heating			
Ambient temp(°C)	15°C	Water flow volume (m³/h)	18m³/h
Voltage (V)	380V	Running time (hrs)	48hrs
Water inlet temp (°C)	20°C	Water outlet temp(°C)	29°C
Testing data when heating			
Test term	Unit	System 1	System 2
Running current	A	10 - 10.2 - 10.5	10.3 - 10 - 10.4
Low pressure	MPa	0.61	0.6
Compressor gas outlet temp.	°C	68	69
Place: Lab 2#	Tester: Mr.Gary	Assessor: Mr.Mark	Result: Pass

