



PSH

CERTIFICATE OF QUALITY

Test Certificate

CONFORMITY OF THE PRODUCT ACCORDING TO THE APPLICABLE REGULATIONS AND TO THE BOMBAS PSH QUALITY STANDARDS

Name and address of the applicant

A-TECHNOLOGIES FZCO
PLOT NO: S20901 NEAR SUMMIT STEEL, SOUTH
OZONE, P.O.BOX 18400,
JABAL ALI FREEZONE, UAE

Product

Cast iron pumps

Model

FDN-1500

Nominal rate and main characteristics

1450rpm – 50Hz – IE3 – IP55
FDN-127H 4HP - 3x230/400V 46 m³/h at 12m
FDN-128 5.5HP - 3x230/400V 70 m³/h at 12m
FDN-129 7.5HP - 3x400/690V 97 m³/h at 12m
FDN-132 15HP - 3x400/690V 125 m³/h at 16m

Standards

Machinery Directive 2006/42/EC.
Low Voltage Directive 2014/35/EU.
Electromagnetic Compatibility Directive 2014/30/EU.
Restrict of Hazardous Substances Directive (RoHS)
Directive 2011/65/EU.
Ecodesign Directive 2009/125/EC, in accordance with
technical standard IEC 60034-30-1:2014.
WEEE Directive 2012/19/EU.

Motor test

Ok

Assembly test

Ok

Balancing of the impeller

Ok

Pressure Decay test

Ok

Flow rate performance test

Not required

OFFICE

CARRER D'ANTONI DE BORJA, 7, ENTLO. 1ª
08191 RUBÍ (BARCELONA) SPAIN
INFO@BOMBASPSH.COM

FACTORY

CARRETERA DE MANRESA A BERGA, S/N
COLÒNIA TÈXTIL EL MOLÍ
08660 BALSARENY (BARCELONA) SPAIN

www.bombasps.com